



GAQF.EX15955 Clean Agent Extinguishing System Units

[Page Bottom](#)

Clean Agent Extinguishing System Units

[See General Information for Clean Agent Extinguishing System Units](#)

FIREFLEX SYSTEMS INC

EX15955

1935 LIONEL BERTRAND
BOISBRIAND, QC J7H 1N8 CANADA

PRE-ENGINEERED UNIT ASSEMBLY, FireFlex 1230 Clean Agent extinguishing system unit, comprised of a single enclosure that houses a Potter Electronic releasing control panel and a SEVO Clean Agent Extinguishing System Unit, utilizing 3MTM Novec™ 1230 Fire Protection Fluid (FK-5-1-12) in agent-charged capacities from 18-273 kg (40-601 lbs), super-pressurized to either 360 psig (25 bar) or 500 psig (34.5 bar).

The units are designed for total-flooding protection against Class A surface burning, Class B flammable liquid and C fires occurring within an enclosure.

A description of these extinguishing system units and the design and installation limitations are contained in the Listee's installation manual FM-0860-0-5B, dated June 2009, or manuals FM-0860-0-10D or FM-0860-0-29A, dated November 2011. Copies are available from the above Listee.

[Last Updated](#) on 2012-05-03

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2012 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2012 UL LLC".